

BACnet Thermostat – Digital and Analog Heating



SPECIFICATIONS

Model	EXL-01642
Fan Speeds	1
Cooling Outputs	0
Heating Outputs	2 Analog Floating 2 Binary
Input Voltage	12-24 V AC/DC
Input Power	5 VA
Output Load Max	1.0 Amps
Relay Output	24 VAC/DC
Analog Output	0-10 VDC
Comm. Line	BACnet MS/TP

PART NUMBER:

EXL-01640 [Options]
Options
RA, DA, RN, TC, MV

FEATURES

- Energy Management System ready with BACnet communications
- Internal Sensor controls 2 modulating heat outputs, 2 Power Open/Power Close heating outputs, and 2 Normally Open/Normally Close heating outputs.
- Setpoints are Limited to internal settings (adjustable)
- Anticycle time delays Protect equipment
- Easy installation and operation
- Stand-alone operation
- Operates Unit Heater, Cabinet Unit Heaters, Infloor heat, and other heating applications

BACnet Thermostat

Description:

This BACnet thermostat operates any heating application. There are two analog outputs, one 0-10 Vdc the other 10-0Vdc, two Power Open/Power Close outputs, and two Normally Open/Normally Closed outputs. Setpoints are adjustable from the BACnet interface. Space temperature setpoints are internally limited by a minimum and maximum setting (adjustable). The thermostat may be placed in the occupied or unoccupied mode. Space temperature is displayed under normal operation. The digital display indicates the current operating mode and outside air temperature (if provided via the BACnet interface).

The unoccupied mode may be overridden by an occupant adjustment up to the maximum allowed hours (adjustable). A manual timer allows from 0.1 to 99.9 hours of occupied operation and then returns to the unoccupied mode.

Infloor Heating can limit infloor temp by setpoint.

Night Setback modulates the heating or cooling when the room temperature is below 60°F or greater than 85°F and continues operation until the setpoint is exceeded by 5°F.

When ordering quantities greater than 30 customized setpoints and additional sequences are available at additional cost, please request a quote for your application.

Relay isolation allows for independent power supply on controlled equipment.

Options:

- RA Monitors Return Air Temperature for Troubleshooting.
- DA Monitors Discharge Air Temperature.
- RN Remote Sensor - Allows the controller to be located in a secure room and the Room Sensor to be in an exterior zone.
- TC Time Clock - Provides an occupancy schedule.
- MV PWM Valve Modulation (Honeywell MV100, Siemens 247 series).



BACnet is a registered trademark of ASHRAE. EXACTLOGIC does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of these products to requirements of ASHRAE Standard 110 is the responsibility of the BACnet thermostat. BTL is a registered trademark of the BTL Testing Laboratory.

